

OFFICE OF THE ASSISTANT EXECUTIVE ENGINEER JAL SHAKTI (PHE) SUB DIVISION
NOWSHERA


CERTIFICATE


It is certified that an inspection team headed by Dr. SUDARSHAN KUMAR Chemist/Lab in-charge under the supervision of Sh. AJAZ AHMED, Assistant Executive Engineer Jal Shakti (PHE) Sub Division Nowshera inspected the Christ High School Nowshera on 24/03/2025.


It is further certified on the basis of water sample test report no. U694864S27955053 Dated 25-03-2025 and inspection done by the technical team on 24-03-2025 that CHRIST HIGH SCHOOL NOWSHERA has safe drinking water facilities. The Technical team also instruct to maintain the hygienic conditions of their water storage tanks and clean them regularly after proper intervals and test their water samples in water testing Laboratory Jal Shakti (PHE) sub Division Nowshera properly so that the students and staff get safe palatable drinking water.


No: PHKSDN/1330

Date: 27/03/2025


Chemist/Lab Incharge
Water Testing Laboratory
Jal Shakti (PHE) Sub Division
Nowshera


Sh. Ajaz Ahmed
Assistant Executive Engineer
Jal Shakti (PHE) Sub Division
Nowshera


Manager
Christ High School
CBSE Affiliation No. 730107
Nowshera, Rajouri, J&K


Sujith Mathew Principal
Christ High School Nowshera
Ward No. 11, Rajouri, J&K-185151
CBSE Affiliation No. 730107

S.D. Water Testing Laboratory, Naushera

Sub division Office, Jal Shakti Department, Naushera. Pin-185151 (Test Address only)

Print

Test report

Sample
Id:

U694864S27955053

User Information

Name:

CHRIST HIGH SCHOOL NOWSHERA

Mobile:

6006858820

Email:

csnowshera@gmail.com

Pin
Code:

185151

Full
Address:

Village- Hanjana Khanka , Gram Panchayat- H. Khanka, Block- Nowshera, District- Rajouri, State- Jammu & Kashmir

Sample description

Source
of
Sample:

CHRIST HIGH SCHOOL NOWSHERA

Village:

Hanjana Khanka

Gram
Panchayat:

H. Khanka

Block:

Nowshera

District:

Rajouri

State:

Jammu & Kashmir

Address:

Remarks:

CHRIST HIGH SCHOOL NOWSHERA

Latitude:

Longitude:

Date & time of sample collection

24.03.2025 | 12:17:00 PM

Date & time of sample received in lab

24.03.2025 | 12:23:00 PM

Date & time of sample analysed

25.03.2025 | 12:52:00 PM

Date & time of report generation

25.03.2025 | 12:54:25 PM

Test results

S. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Method of Analysis	Remarks
1	Calcium (as Ca)	mg/l	75	200	97.000	FTK	Ok
2	E. coli	CFU/100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	H2S vial test	Ok
3	Iron (As Fe)	mg/l	1	No Relaxation	0.200	FTK	Ok
4	Nitrate (as NO ₃)	mg/l	45	No Relaxation	29.000	FTK	Ok
5	pH	NA	6.5-8.5	No Relaxation	7.300	Instrumental method	Ok
6	TDS	mg/l	500	2000	399.000	Instrumental method	Ok
7	Total Alkalinity (as Calcium Carbonate)	mg/l	200	600	192.000	FTK	Ok
8	Total Hardness (As CaCO ₃)	mg/l	200	600	193.000	FTK	Ok
9	Turbidity	NTU	1	5	1.450	Nephelometric method	Ok

Note:

- 1)*indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Data prepared by

Chemist: (Dr.Sudarshan Kumar)

Microbiologist: (Dr.Sudarshan Kumar)

Authorised signatory

Dr. Sudarshan Kumar (Test Lab Incharge)

*****This is an electronically generated report and does not require a signature.*****

Jal Jeevan Mission aims at potable tap water supply to every home

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC. Copyright ©copy NJJM 2025

Print

GOVERNMENT OF JAMMU & KASHMIR
OFFICE OF THE BLOCK MEDICAL OFFICER (H&F:W) NOWSHERA
Tel Fax: 01960-230268 Email: bmonowshera12@gmail.com

HEALTH FACILITIES CERTIFICATE

This is to certify that Christ High School Nowshera is situated in Nowshera Ward No.11 has sufficient First Aid facilities and emergency medicines with them. Besides that, there are sufficient vehicles and drivers all time to take the students to the hospital if any casualties or emergency. In case of any health requirement of the students and staff of above-mentioned school, the health institution will fulfil the needs including health emergencies.


No:BMO/NSR/2025-26/3201


Dated 03/01/2025


Block Medical Officer
Nowshera

Copy to the:-

01. Principal Christ High School Nowshera for information.


Sujith Mathew Principal
Christ High School Nowshera
Ward No. 11, Rajouri, J&K-185151
CBSE Affiliation No. 730107


Manager
Christ High School
CBSE Affiliation No. 730107
Nowshera, Rajouri, J&K